



THE CITY OF SAN DIEGO

## Fire-Rescue Department

### Sprinkler Policies Policy FS - 0415

---

#### ***Waterflow Alarm***

Buildings whose sprinkler systems are designed in accordance with NFPA 13 or 13R shall locate the waterflow alarm on the address side of the building or within 15 feet down either side

In single family homes and duplexes which have sprinklers installed in accordance with NFPA 13 D, the waterflow alarm shall be in a location which optimizes the chance that occupants sleeping in the dwelling shall hear the alarm.